

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 3230-1722:102

Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: United Enertech Corp., 3005 S. Hickory Street, Chattanooga, TN 37407
 Contact: Dane Carey (423) 643-2548 Fax (888) 713-3285
 dcarey@unitedenertech.com

DESIGN: Models F/S-3V-I, F/S-3V-II, F/S-3V-3-I, F/S-3V-3-II, F/S-3V-CR-I, F/S-3V-CR-II, S-3V-I and S-3V-II leakage dampers. Refer to listee's data sheet for additional detailed product description and operational considerations.

Models	Position	Single Section				Multiple Assemblies		Rating
		Width		Height		Width	Height	
		Min.	Max.	Min.	Max.	Max.	Max.	
F/S-3V-I	V	8"	36"	6"	48"	108"	96"	I-350
	H	8"	36"	6"	48"	72"	96"	I-350
F/S-3V-II	V	6"	36"	6"	48"	108"	96"	II-350
	H	6"	36"	6"	48"	72"	96"	II-350
F/S-3V-3-I	V	8"	36"	6"	48"	72"	48"	I-350
	H	8"	36"	6"	48"	72"	48"	I-350
F/S-3V-3-II	V	6"	36"	6"	48"	72"	48"	II-350
	H	6"	36"	6"	48"	72"	48"	II-350
F/S-3V-CR-I	V	6"	24"	6"	24"	NA	NA	I-350
	H	6"	24"	6"	24"	NA	NA	I-350
F/S-3V-CR-II	V	6"	24"	6"	24"	NA	NA	II-350
	H	6"	24"	6"	24"	NA	NA	II-350
S-3V-I	V	8"	36"	6"	48"	144"	96"	I-350
	H	8"	36"	6"	48"	144"	96"	I-350
S-3V-II	V	8"	36"	6"	48"	144"	96"	II-350
	H	8"	36"	6"	48"	144"	96"	II-350

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification rating, and UL label.

APPROVAL: Listed as Class I and II leakage rated dampers for use in 1-1/2 or 3 hours rated locations except for Models S-3V-I and S-3V-II which are intent for use in non-fire rated locations. Refer to listee's Installation Instruction Manual for details.

02-13-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 25, 2009**

Listing Expires June 30, 2009

Authorized By: **BEN HO, Chief**
 Fire Engineering Division